

Figure: 30 TAC §115.112(a)(1)

Table I(a): Required Control for a Storage Tank Storing Volatile Organic Compounds (VOC) Other than Crude Oil and Condensate

True Vapor Pressure (pounds per square inch absolute (psia))	Storage Capacity (gallon (gal))	Control Requirements
≥ 1.5 psia and < 11 psia	$> 1,000$ gal and $\leq 25,000$ gal	Submerged fill pipe or Vapor control system
≥ 1.5 psia and < 11 psia	$> 25,000$ gal and $\leq 40,000$ gal	Internal floating <u>roof</u> [cover], or External floating roof (any type), or Vapor control system
≥ 1.5 psia and < 11 psia	$> 40,000$ gal	Internal floating <u>roof</u> [cover], or External floating roof with primary seal (any type) and secondary seal, or Vapor control system
≥ 11 psia	$> 1,000$ gal and $\leq 25,000$ gal	Submerged fill pipe or Vapor control system
≥ 11 psia	$> 25,000$ gal	Submerged fill pipe and Vapor control system

Table II(a): Required Control for a Storage Tank Storing Crude Oil and Condensate

True Vapor Pressure (pounds per square inch absolute (psia))	Storage Capacity (gallon (gal))	Control Requirements
≥ 1.5 psia and < 11 psia	$> 1,000$ gal and $\leq 40,000$ gal	Submerged fill pipe or Vapor control system
≥ 1.5 psia and < 11 psia	$> 40,000$ gal	Internal floating roof, or External floating roof with primary seal (any type) and secondary seal, or Vapor control system
≥ 11 psia	$> 1,000$ gal and $\leq 40,000$ gal	Submerged fill pipe or Vapor control system
≥ 11 psia	$> 40,000$ gal	Submerged fill pipe and Vapor control system