

Figure: 30 TAC §115.112(c)(1)

Table I(b). Required Control for a Storage Tank Storing Volatile Organic Compounds (VOC) Other than Crude Oil and Condensate

True Vapor Pressure (pounds per square inch absolute (psia))	Storage Capacity (gallon (gal))	Control Requirements
≥ 1.5 psia and < 11 psia	> 1,000 gal and ≤ 25,000 gal	Submerged fill pipe or Vapor control system
≥ 1.5 psia and < 11 psia	> 25,000 gal	Internal floating roof or external floating roof (any type) or Vapor control system
≥ 11 psia	> 1,000 gal and ≤ 25,000 gal	Submerged fill pipe or Vapor control system
≥ 11 psia	> 25,000 gal	Submerged fill pipe and Vapor control system