

Figure: 30 TAC §285.81(d)

Table II. Adjusted Organic Strength

Sewage sources entering a graywater reuse system or a combined reuse system	Five- day Biochemical Oxygen Demand (BOD₅) design strength for sewage entering on- site sewage facilities milligrams per liter (mg/l)
Clothes-washing machine only	375
Showers, bathtubs, hand-washing lavatories, and sinks that are not used for the disposal of hazardous or toxic ingredients	430
Clothes-washing machines, showers, bathtubs, hand-washing lavatories, and sinks that are not used for the disposal of hazardous or toxic ingredients	600