

Figure: 30 TAC §312.126(a)

TABLE 10 - FREQUENCY OF MONITORING - WATER TREATMENT RESIDUALS

Amount of water treatment residuals* (metric tons per 365- day period)	Frequency
0 to less than 290	once per year
290 to less than 1,500	once per quarter
1,500 to less than 15,000	once per 60 days
15,000 or greater	once per month

* Either the amount of bulk water treatment residuals land applied, or the amount of water treatment residuals received by a person who prepares the water treatment residuals for land application - dry weight basis.