

Figure: 30 TAC §317.2(d)(4)

$$L = \frac{S \times D \times \sqrt{P}}{133,200}$$

Where:

L = leakage in gal/hr

S = length of pipe in ft

D = inside diameter of pipe in inches

P = pressure in pounds per square inch